


Holderness Coast (Gypsey Race) Strategic Planning Area







Key Strategic Planning Area Statistics			
Number of WwTW Catchments	75		
Population Equivalent in 2020	204,167		
Population Equivalent in 2050	233,247		
Population Equivalent Growth	14%		
Modelled Consented Storm Overflows	48		
Wastewater Pumping Stations	266		
Foul and Combined Sewer Length	835km		
Surface Water Sewer Length	265km		
Catchments Passed Through To BRAVA	40		



National Baseline Risk and Vulnerability Assessment								
Internal Sewer Flooding 2020 Score	Pollution Risk 2020 Score	Sewer Collapse Risk 2020 Score	Risk of Sewer Flooding (1 in 50) 2020 Score	Risk of Sewer Flooding (1 in 50) 2050 Score	Storm Overflow Performance 2020 Score	Storm Overflow Performance 2050 Score	Risk of WwTW Compliance Failure 2020	Risk of WwTW Compliance Failure 2050
2	2	0	1	1	1	1	0	0



BRAVA Outcome Summary		
Promote	Develop strategic catchment based solution options to address predicted risks and look for potential opportunities for partnership working	
Investigate	Work to understand in more detail the size and scale of the predicted catchment risk	
Monitor	Continue to monitor all potential risks in the catchment and promote once a suitable threshold is breached	
Observe	Did not trigger the required number of indicators in the RBCS process so therefore was not assessed against any criteria but will be reviewed in future DWMP cycles	

Copyright Yorkshire Water Services Ltd 2022 Contains OS data © Crown Copyright and database right 2020 Contains data from OS Zoomstack

25-Year Strategic Plan – How much do we need to invest?



Annual average of no more than 10 spills per storm overflow and reduced levels of property flood risk from hydraulic sewer flooding and ensure our WwTWs have sufficient capacity to allow us to remain compliant with our current environmental permits.

Annual average of no more than

10 spills per storm overflow, plus

no environmental harm from

storm overflows and reduced

from hydraulic sewer flooding and ensure our WwTWs have

sufficient capacity to allow us

to remain compliant with our

current environmental permits.

levels of property flood risk



Scenario

Annual average of no more than 10 spills per storm overflow and maintain regional level of property flood risk from hydraulic sewer flooding and ensure our WwTWs have sufficient capacity to allow us to remain compliant with our current environmental permits.

Annual average of no more than 10 spills per storm overflow, plus no environmental harm from storm overflows and maintain regional level of property flood risk from hydraulic sewer flooding and ensure our WwTWs have sufficient capacity to allow us to remain compliant with our current environmental permits.

Level 2 Holderness Coast (Gypsey Race) 25-Year Lowest Cost Plan Range		Level 2 Holderness Coast (Gypsey Race) 25-Year Best Value Plan Cost Range			
Scenario 1	£0.3 billion	£0.9 billion	Scenario 1	£0.4 billion	£1.1 billion
Scenario 2	£0.3 billion	£0.9 billion	Scenario 2	£0.4 billion	£1.2 billion
Scenario 3	£0.1 billion	£0.3 billion	Scenario 3	£0.3 billion	£0.9 billion
Scenario 4	£0.1 billion	£0.3 billion	Scenario 4	£0.3 billion	£0.9 billion

The risk position and subsequent outcome is a result based on the DWMP framework. The baseline and future performance of our catchments will be incorporated into our standard business planning processes and may result in some catchments changing classification and will be prioritised accordingly.