

YORKSHIRE OUSE AND HULL RIVER AUTHORITY

Water Resources Act 1963 - Water Resources (Licences) Regulations 1965

LICENCE OF RIGHT TO ABSTRACT WATER

THE YORKSHIRE OUSE AND HULL RIVER AUTHORITY (hereinafter referred to as "the River Authority") hereby grant a licence to—

OFFICE COPY
from 1/4/74
Wals. Dec 1973

~~Craven Water Board, Yorkshire Water Authority~~
~~Belmont Bridge, Sackville Street,~~
~~Skipton, Yorks. BD23 2EG.~~

Application No. 2922

VARIATION

(hereinafter referred to as "the licence holder") to abstract water from the source of supply described in the Schedule hereto, subject to the provisions specified in such Schedule.

This licence shall remain in force until revoked.

Fees and Charges. The fee payable by the licence holder under Section 57 of the Act on the grant of this licence and annually thereafter is £ 5.0.0. (or such other sum as is for the time being prescribed by order of the Minister of Housing and Local Government). In addition, charges may be payable pursuant to Part V of the Act in respect of the quantity of water authorised to be abstracted under this licence.

SCHEDULE

Varied in accordance with a resolution of the Water Resources Committee dated 27th June, 1973.

Source of supply and authorised place(s) of abstraction

Embsay reservoir SD 998546
SE 004545 Mill Beck

D. Chworth
Chief of the Authority

Authorised means of abstraction

Valves and pipelines from reservoir

Land on which water is authorised to be used

N/A

Purpose for which water is authorised to be used

Water Undertaking.

The quantity of water authorised to be abstracted shall be provided the maximum rate of abstraction shall not exceed or

(1,846 Ml/a)
406 million gallons per annum
- gallons per day
- gallons per hour

~~The quantity of water authorised to be abstracted shall be measured by a meter. The meter shall be approved by the Authority and maintained in good working order, and the quantity measured by the meter is to be taken to be the quantity of water abstracted~~

A meter of a pattern to be approved by the River Authority shall be installed to measure the quantity of water abstracted and the quantity so measured shall be taken to be the quantity abstracted.

The meter shall be maintained in good working order and shall be read monthly. Records shall be kept of the readings and shall be produced on request to Officers of the River Authority at all reasonable times.

FOR SPECIAL CONDITIONS SEE OVER

The variation of this licence is approved subject to the following conditions:-

1. Satisfactory detail plans, sections and elevations of the design and materials of construction of the intake and of the arrangements for securing the passage of the prescribed flow referred to in condition 2 hereof shall be submitted to and approved by the River Authority before any work is commenced.
2. A flow of not less than 0.273 Ml/d (60,000 g.p.d.) shall remain in Mill Beck immediately downstream of the abstraction point during all periods when abstraction takes place under this variation.