

From: EIR Compliance

To:

Subject: 20251231- EIR

Date: 31 December 2025 13:55:46

Attachments: EIR Request - Dec 25 - PFAS. Lead Data - Richmond 2.csv

EIR Request - Dec 25 - PFAS. Lead Data - Richmond 3.csv

EIR Request - Dec 25 - PFAS. Lead Data - Richmond 1.csv

Reference Number: **EIR**

Dear

We refer to your request for information submitted to Yorkshire Water dated 16 December 2025:

"1. Source of Domestic Water Supply

• The origin(s) of the water supplied to this location (e.g., reservoir, groundwater, river abstraction points).

• Any intermediate treatment works or distribution zones that serve this address.

2. Water Quality Testing Results

Please provide the most recent available results (and dates of testing) for:

- Lead*
- PFAS (per- and polyfluoroalkyl substances), including but not limited to PFOS, PFOA, and other routinely monitored PFAS compounds.*

3. Any exceedances or issues noted in testing for lead or PFAS within the relevant supply zone during the past 24 months."

Please find attached the data which you have requested. Included with this email is our response to your questions:

1. **Source of water supply:**

Your water supply system is Catterick, and this system can potentially receive water from four different water treatment works - Thornton Steward, Catterick, Dalton or Richmond. The sources that supply those water treatment works can either be groundwater from a borehole or springs or surface water from the River Ure abstraction point or local reservoirs.

2. **Water quality testing results.**

Please see attached the last 12 months of PFAS sample results for the raw water sources that can provide water to the Catterick water supply system. As per the DWI PFAS guidance, Yorkshire Water monitor for 48 PFAS compounds. All raw water abstraction points are monitored for PFAS and should the level of PFAS concentrations increase, then treated water samples are taken. The raw water sources that provide water for the Richmond area are in tier 1 and are often below the limit of detection and so treated water sampling is not required. There is no regulatory limit for PFAS, however the DWI has created a tier system for PFAS detections and associated required actions which Yorkshire Water follows. Your water supply is in tier 1 for PFAS and has not had any tier 2 or 3 PFAS detections in the last 24 months.

Regarding lead, you can find the latest available water quality report for their zone on the Yorkshire Water website and put in your postcode. This report is only for 2024 and confirms no failures for lead during this time. Please see attached recent lead results for your water supply zone - Catterick/ Richmond for 2025. The results also confirm no exceedance for lead in 2025 for your water supply zone.

We trust that the provision of this data satisfies your request. In accordance with the Environmental Information Regulations 2004, if you are not satisfied with this reply to your request you can ask for an internal review. A request for an internal review must be submitted within 40 working days by contacting the Data Protection Team.

Thank you for contacting Yorkshire Water.

Yours sincerely,

Data Protection Team

Email: EIR@Yorkshirewater.co.uk