

|                           |        |                             |
|---------------------------|--------|-----------------------------|
| Environment<br>Reference: | Agency | DP2022 –<br>2/27/19/129/R01 |
|---------------------------|--------|-----------------------------|



## Drought Permit – modify existing abstraction

Section 79A Water Resources Act 1991 as amended by the Environment Act 1995

The Environment Agency grants this drought permit to:

Yorkshire Water Services Limited (“the Water Company”)  
 Western House  
 Halifax Road  
 Bradford  
 West Yorkshire  
 BD6 2SZ

Company registration number      02366682

This drought permit modifies Licence number 2/27/19/129/RO1 dated 24 January 2018 as set out in the Schedule to this drought permit. This drought permit commences from the effective date shown below and shall remain in force until the date of expiry shown below.

All other provisions of the licence remain in full force and effect.

|   |                             |                      |
|---|-----------------------------|----------------------|
| <b>Signed</b> <b>Type name</b><br>Area Director                         | <b>Date of issue</b> .....  | <b>DD MONTH YYYY</b> |
| Environment Agency<br>Lateral House<br>8 City Walk<br>Leeds<br>LS11 9AT | <b>Date effective</b> ..... | <b>DD MONTH YYYY</b> |
|   | <b>Date of expiry</b> ..... | <b>DD MONTH YYYY</b> |

|                           |        |                             |
|---------------------------|--------|-----------------------------|
| Environment<br>Reference: | Agency | DP2022 –<br>2/27/19/129/R01 |
|---------------------------|--------|-----------------------------|

## SCHEDULE OF CONDITIONS

### 1 MODIFICATION OF LICENCE NUMBER: 2/27/19/129/R01

#### 1.1 Condition 9.8 of licence number 2/27/19/129/R01 is replaced by the following;

The aggregate daily abstraction authorised under this licence and licence serial number 2/27/20/196/R01 (Arthington) shall be equal to the quantity of water released from Grimwith Reservoir and shall not exceed 88.6 Ml/d when the flow in the River Wharfe as gauged by the Agency at its flow gauging station at Addingham Low Mill at National Grid Reference SE09147 49299 is equal to or less than 252 Ml/d (2.917 cumecs) as may be notified by the Agency. The Agency's said gauging of the flow shall be conclusive."